

# IAPMO RESEARCH AND TESTING, INC.

5001 East Philadelphia Street, Ontario, California 91761-2816 – USA • 909-472-4100 • 909-472-4244 • www.iapmort.org



NSF/ANSI 61

## CERTIFICATE OF LISTING

IAPMO Research and Testing, Inc. is a product certification body which tests and inspects samples taken from the supplier's stock or from the market or a combination of both to verify compliance to the requirements of applicable codes and standards. This activity is coupled with periodic surveillance of the supplier's factory and warehouses as well as the assessment of the supplier's Quality Assurance System. This listing is subject to the conditions set forth in the characteristics below and is not to be construed as any recommendation, assurance or guarantee by IAPMO Research and Testing, Inc. of the product acceptance by Authorities Having Jurisdiction.

This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)

Effective Date: April 2019

Void After: April 2024

Product: Drinking Water System Components - Health Effects

File No. N-10519

Issued To: Ecofinish, LLC  
415 Constance Drive  
Warminster, PA 18974

Identification: Each product shall be permanently and legibly marked with the manufacturer's name or trademark. The product may also be marked with the standard designation "NSF/ANSI 61".

Characteristics: Materials or products that come into contact with drinking water and/or drinking water treatment chemicals. Products and materials may include process media, protective materials, joining and sealing materials, pipes and related products, mechanical devices used with treatment/transmission/distribution systems, and mechanical plumbing devices. To be installed in accordance with the manufacturer's instruction. Lead free requirements are addressed under a separate certificate of listing.

Products listed on this certificate have been tested by an IAPMO R&T recognized laboratory. This recognition has been granted based upon the laboratory's compliance to the applicable requirements of ISO/IEC 17025.

Products are in compliance with the following standard(s):

  
Chairman, Product Certification Committee

  
CEO, The IAPMO Group



This listing period is based upon the last date of the month indicated on the Effective Date and Void After Date shown above. Any change in material, manufacturing process, marking or design without having first obtained the approval of the Product Certification Committee, or any evidence of non-compliance with applicable codes and standards or of inferior workmanship, may be deemed sufficient cause for revocation of this listing. Production of or reference to this form for advertising purposes may be made only by specific written permission of IAPMO Research and Testing, Inc. Any alteration of this certificate could be grounds for revocation of the listing. This document shall be reproduced in its entirety.

**IAPMO RESEARCH AND TESTING, INC.**  
**CERTIFICATE OF LISTING**

**NSF/ANSI 61**

Void After: April 2024

Product: Drinking Water System Components - Health Effects

File No. N-10519

Issued To: Ecofinish, LLC

NSF/ANSI 61-2017

# IAPMO RESEARCH AND TESTING, INC.

## CERTIFICATE OF LISTING

NSF/ANSI 61

*This certificate is not evidence of current listing. To verify listing status, visit the IAPMO R&T Product Listing Directory at [pld.iapmo.org](http://pld.iapmo.org)*

Void After: April 2024

Product: Drinking Water System Components - Health Effects

File No. N-10519

Issued To: Ecofinish, LLC

MODELS:

Model No.

Black 2011,  
Blue 2025  
Blue Nile 2032  
Brown 2034  
Cali Blue 2036  
Dark Gray 2021  
Glow Blue 2029P  
Glow Green 2030p.  
Green 2031  
Grey Tile 2039P  
Ivory 2015  
Light Blue 2012  
Light Gray 2014  
Medium Blue 2013  
Orange 2038P  
Red 2040P  
Royal Blue 2035  
Tan 2023  
White 2010  
Yellow 2024  
Yellow 2037P

a - For use with tanks greater than or equal to 2,000 gallons, not exceeding a surface area to volume ratio of 29.0 cm<sup>2</sup>/L; Mix Ratio: N/A; Number of coats = 2 - 3 coats of powder; Application Method: Flame Spray; Maximum dry film thickness= 15 mils; Thinner= N/A; Cure Time= Instant. This product was tested without an additional primer or topcoat. It is recommended that any primer or topcoat used should be certified to NSF/ANSI Standard 61.